



HAZARDOUS AREA      SAFE AREA

USE	BARRIER ID. #
+ EXCITATION	9001/01-083-442-10
+ SENSE	9001/02-133-150-10
- EXCITATION	9001/00-083-442-10
- SENSE	9001/02-133-150-10
SIGNAL A ±	9002/22-093-040-00

- NOTES**
- ALL DIMENSIONS ARE INCHES ( ) DENOTES mm.
  - USED WITH ACCUMASS BW500.
  - FOR CABLE RUNS OVER 500 FT. JUMPERS J1 & J2 MUST BE REMOVED AND ADDITIONAL CONDUCTORS SUPPLIED.

2 REMOVE CONFIDENTIAL INFORMATION PER ECN 2004-0001		RPC	PTR	FEB 24/2004
1 CHANGE TITLE & ADD SF500, BW100 PER ECN 2002-0147		RPC	PTR	JUNE 18/02
USE DIMENSIONS ONLY - DO NOT SCALE				
DIMENSIONS ARE IN INCHES				
Rev.	Revision / ECN Description	Drawn	Appr.	Date
Third Angle Projection		Product Group	Tolerance Unless Otherwise Noted:	Scale:
		MASS DYNAMICS	UOS 1 Place Decimal ± 0.03 2 Place Decimal ± 0.01 3 Place Decimal ± 0.002	Angles: ± 0.5° NTS
Date: 19 FEB 99		Drawn: R. CLYSDALE	TITLE: STAHL BARRIER PKG., ONE LOAD CELL & INTEGRATOR INTERCONNECTION DRAWING	
Checked: P. RICCI		Approved: R. CLOSS	DRAWING No: 23650344	
Location: PETERBOROUGH		SIEMENS MILLTRONICS PROCESS INSTRUMENTS INC. Peterborough, Ontario, Canada	Rev. 2	
File No. 2365034402		Plot at: 1=1	Sheet 1 Of 1	

**For Public Release**