



HAZARDOUS AREA **SAFE AREA**

TO
BW500/SF500 **BW100**

TB1 **TB1**

USE	BARRIER ID. #
+ EXCITATION	9001/01-083-442-10
+ SENSE	9001/02-133-150-10
- EXCITATION	9001/00-083-442-10
- SENSE	9001/02-133-150-10
SIGNAL A ±	9002/22-093-040-00
SIGNAL B ±	9002/22-093-040-00

- NOTES**
- ALL DIMENSIONS ARE INCHES () DENOTES mm.
 - USED WITH ACCUMASS BW500.
 - FOR CABLE RUNS OVER 500 FT. JUMPERS J1 & J2 MUST BE REMOVED AND ADDITIONAL CONDUCTORS SUPPLIED.

2	REMOVE CONFIDENTIAL NOTICE PER ECN 2004-0001	RPC	PTR	FEB 23/2004
1	CHANGE TITLE & ADD SF500, BW100 PER ECN 2002-0147	RPC	PTR	JUNE 18/02

USE DIMENSIONS ONLY - DO NOT SCALE		REPLACES 0-7330002Z-DI-B REV 0	
DIMENSIONS ARE IN INCHES		Rev.	Revision / ECN Description
	Product Group	Tolerance Unless Otherwise Noted:	Scale:
	MASS DYNAMICS	1 Place Decimal ± 0.03 2 Place Decimal ± 0.01 3 Place Decimal ± 0.002	NTS
For Public Release	Date:	TITLE:	
	19 FEB 99	STAHL BARRIER PKG., TWO LOAD CELLS & INTEGRATOR INTERCONNECTION DRAWING	
	Drawn: R. CLYSDALE	DRAWING No:	
	Checked: P. RICCI	23650343	
	Approved: R. CLOSS	Rev. 2	
Location: PETERBOROUGH	SIEMENS MILLTRONICS PROCESS INSTRUMENTS INC. Peterborough, Ontario, Canada	Plot at:	Sheet 1 Of 1
File No. 2365034302		1=1	