



HAZARDOUS AREA | SAFE AREA

USE	BARRIER ID. #
+ EXCITATION	9001/01-083-442-10
+ SENSE	9001/02-133-150-10
- EXCITATION	9001/00-083-442-10
- SENSE	9001/02-133-150-10
SIGNAL A ±	9002/22-093-040-00

- NOTES**
- ALL DIMENSIONS ARE INCHES () DENOTES mm.
 - USED WITH ACCUMASS BW500.
 - FOR CABLE RUNS OVER 500 FT. JUMPERS J1 & J2 MUST BE REMOVED AND ADDITIONAL CONDUCTORS SUPPLIED.

2 REMOVE CONFIDENTIAL INFORMATION PER ECN 2004-0001		RPC	PTR	FEB 24/2004
1 CHANGE TITLE & ADD SF500, BW100 PER ECN 2002-0147		RPC	PTR	JUNE 18/02
USE DIMENSIONS ONLY - DO NOT SCALE				
DIMENSIONS ARE IN INCHES				
Rev.	Revision / ECN Description	Drawn	Appr.	Date
Third Angle Projection		Product Group: MASS DYNAMICS		Tolerance Unless Otherwise Noted: UOS
Date: 19 FEB 99		Date: 19 FEB 99		Scale: NTS
Drawn: R. CLYSDALE		Checked: P. RICCI		Size: B
Approved: R. CLOSS		TITLE: STAHL BARRIER PKG., ONE LOAD CELL & INTEGRATOR INTERCONNECTION DRAWING		
Location: PETERBOROUGH		DRAWING No: 23650344		
SIEMENS MILLTRONICS PROCESS INSTRUMENTS INC. Peterborough, Ontario, Canada		Rev. 2		
File No. 2365034402		Plot at: 1=1		Sheet 1 Of 1

For Public Release